

BILL/ RESOLUTION REQUEST

1. Title: Approves a contract with Trautman & Shreve, Inc. for 540 days and a contract amount of \$7,382,465 for the Hydronic System Optimization Project at Denver International Airport.

2. Requesting Agency: DIA

3. Contact Person *with actual knowledge of proposed ordinance*

Name:Bruce Evans

Phone:303-342-4455

Email:Bruce.Evans@flydenver.com

4. Contact Person *with actual knowledge of proposed ordinance who will present the item at Mayor Council and who will be available for first and second reading, if necessary*

Name:Brian Elms

Phone:303-619-7353

Email:brian.elms@flydenver.com

5. Describe the proposed ordinance, including what the proposed ordinance is intended to accomplish, who's involved

a. Scope of Work

Contract Execution for Hydronic System Optimization Project #2011-02945 award to Trautman & Shreve, Inc.

This project will remove all the tertiary building pumps and proprietary BRDG-TNDR controls. New independent pressure controls valves will be installed at each air handling unit. The controls for each air-handling unit and each secondary building pump will be modified for the control sequences. (HVAC up-date) removing and upgrading the system throughout the airport.

b. Duration

540 Calendar Days from NTP

c. Location

DIA

d. Affected Council District

11

e. Benefits

Essential System Upgrade

f. Costs

\$7,382,465

6. Is there any controversy surrounding this ordinance, groups or individuals who may have concerns about it? Please explain.

No

Bill Request Number: BR12-0082

Date: 1/24/2012