

CITY AND COUNTY OF DENVER

DEPARTMENT OF PUBLIC WORKS

Development Engineering Services Public Works Permit Operations

2000 W. THIRD AVENUE, ROOM 107 DENVER, COLORADO 80223-1027 Phone: (303) 446-3759/ Fax: (303) 446-3755 http://www.denvergov.org/PWPermits

Permit Number

200910118

Application Conditions

APPLICATION CONDITIONS TO BE MET <u>PRIOR</u> TO ISSUANCE OF SEWER USE & DRAINAGE PERMIT

Project Name: WASTE MANAGEMENT BLDG (DENVER ZOO)

Address: 3200 E 23rd Ave Bldg 31108

Please respond to the WMD Permit Counter at the address in the letterhead.

 Agent Name:
 STEVE SALG
 Agent Phone:
 (303) 376-4983

 Agent Address:
 2300 STEELE ST
 Agent Fax:
 (303) 376-4897

Agent City/State/Zip: DENVER, CO 80205

	•		
NUMBER	CONDITION	DATE SIGNED-OFF	SIGNED-OFF BY
1	The Industrial Waste Survey (IWS) must contain information on the specific use and type of wastes (industrial, domestic, etc.) generated and discharged to the sanitary sewer system of the subject building. Owner shall submit the IWS with pertinent information on the waste management processes that will take place inside the building. AdeS 11/03/2009	02/18/2010	de Spirlet, Andre
2	The building sewer line serving the existing building to be demolished or moved must be properly cut-off, and then inspected by PW WMD, prior to issuance of a Sewer Use & Drainage Permit for any new building(s). If the cutoff location cannot be made as required by PW WMD, the licensed plumbing or sewer contractor shall coordinate with PW WMD Plumbing Inspection to have the inspection pre-cleared. ELC 11/13/2009	02/11/2010	Cordova, Ed
	The PW WMD Plumbing Inspector must also verify if the existing structure(s) to be demolished are on a septic system or connected to storm, if no building sewer connection is tied to the sanitary sewer system. Also, all domestic water tap sizes that service the existing buildings to be domolished must be verified and documented by the PW WMD Plumbing Inspector as part of the cutoff inspection. This information is necessary for applying applicable credits towards the Sewer Connection charges. ELC 11/13/2009		
3	ABSOLUTELY NO PORTION OF ANY OLD/CUTOFF BUILDING SEWER LINE WHICH SERVED ANY BUILDING ON THIS SITE WILL BE ALLOWED TO BE REUSED. ELC 11/13/2009	02/11/2010	Cordova, Ed
4	An Application for a Construction Activities Stormwater Discharge Permit accompanied by a Construction Activities Stormwater	02/11/2010	Cordova, Ed

Printed On: 03/02/2010 Page 1 of 2



CITY AND COUNTY OF DENVER

DEPARTMENT OF PUBLIC WORKS

Development Engineering Services Public Works Permit Operations

2000 W. THIRD AVENUE, ROOM 107 DENVER, COLORADO 80223-1027 Phone: (303) 446-3759/ Fax: (303) 446-3755 http://www.denvergov.org/PWPermits

Permit Number

200910118

Application Conditions

APPLICATION CONDITIONS TO BE MET PRIOR TO ISSUANCE OF SEWER USE & DRAINAGE PERMIT

NUMBER CONDITION

Management Plan (CASMP) must be submitted to the Wastewater Management Division for review and approval prior to the issuance of this Sewer Use and Drainage Permit. Issuance of the Construction Activities Stormwater Discharge Permit is required prior to the startup of any construction, demolition or other site disturbing operations DAVE STEVER 11/20/2009

The Construction Activities Stormwater Management Plan submitted as supporting documentation for the Construction Activities Stormwater Discharge Permit, shall conform to the content requirements identified in the WMD publication entitled "Construction Activities Stormwater Management Plan, An Information Guide", dated 2006 DAVE STEVER 11/20/2009

- Wastes generated from the processing areas will contain a high solids content. Submit revised plumbing plans showing a minimum 200-gallon solids interceptor located UPSTREAM from the domestic sanitary waste connection(s) serving the maintenance area and utility room. No domestic waste is allowed to flow through the pretreatment device. AdeS 02/25/2010
- Stormwater flows into the sanitary sewer system is prohibited. Submit details of the exterior trash shredder pad and dumpster scale areas showing stormwater flows being diverted away from the sanitary floor drains. AdeS 02/25/2010

DATE SIGNED-OFF SIGNED-OFF BY

Printed On: 03/02/2010 Page 2 of 2