

ORDINANCE/RESOLUTION REQUEST

Please email requests to the Mayor's Legislative Team
at MileHighOrdinance@DenverGov.org by **3:00pm on Monday**.

All fields must be completed.

Incomplete request forms will be returned to sender which may cause a delay in processing.

Date of Request: November 15, 2017

Please mark one: Bill Request or Resolution Request

1. Has your agency submitted this request in the last 12 months?

Yes No

If yes, please explain:

2. **Title:** (Include a concise, one sentence description – please include name of company or contractor and contract control number - that clearly indicates the type of request: grant acceptance, contract execution, amendment, municipal code change, supplemental request, etc.)

The Public Service Company of Colorado contract (GENRL-CE2Y000-02) for chilled water services is being amended to add language regarding the installation of a new temperature override system and applicable rate charges for this system which will be located at the Denver Art Museum.

3. **Requesting Agency:** General Services

4. **Contact Person:** (With actual knowledge of proposed ordinance/resolution.)

- **Name:** Nicol Suddreth
- **Phone:** 720-865-7508
- **Email:** Nicol.Suddreth@denvergov.org

5. **Contact Person:** (With actual knowledge of proposed ordinance/resolution who will present the item at Mayor-Council and who will be available for first and second reading, if necessary.)

- **Name:** Andrea Fulton
- **Phone:**
- **Email:** AKFulton@denverartmuseum.org

6. **General description of proposed ordinance including contract scope of work if applicable:**

The 2nd amendment will add language to the contract regarding the installation of a new chilled water supply temperature override control system and the charges associated with operating this new temperature control system. The amendment will also amend the annual adjustment language to now include the new supply temperature override consumption charge rates.

****Please complete the following fields:** (Incomplete fields may result in a delay in processing. If a field is not applicable, please enter N/A for that field.)

a. **Contract Control Number:** CE2Y000-02

b. **Duration:** 1/1/2002 – 6/30/2026

c. **Location:** Denver Art Museum – 100 West 14th Avenue, Denver, CO 80202

d. **Affected Council District:** 10

e. **Benefits:** With the addition of the temperature override system, this will allow the Denver Art Museum (DAM) staff the ability to adjust the chilled water temperature if the control system is unable to maintain the required humidification levels within the galleries at DAM.

f. **Costs:**

7. **Is there any controversy surrounding this ordinance?** (Groups or individuals who may have concerns about it?) **Please explain:**

No controversy that General Services is aware of.

To be completed by Mayor's Legislative Team:

SIRE Tracking Number: _____

Date Entered: _____